



ENQUIRY NO:

PROJECT:

PACKAGE: INDUCED DRAFT COOLING TOWER (IDCT)

1. The bidder should have designed, constructed and commissioned the Induced draft cooling towers (IDCT) with cross/counter flow with splash/film type fill in RCC construction with minimum flow of 13000 Cum/hr, which have been successfully in use for at least 1 year in two different thermal power plant or similar industry/ application of two different customers and bidder is in business of IDCT on continuous basis.

Bidder to comply to general points of PQR available at <http://bhhelpem.com/vensection/PMD/PMD.aspx> . In case bidder is not OEM, the offer shall be evaluated as per point no 1 of general points of PQR.

2. The Bidders shall furnish following support documents for assessment of Bidder w.r.t. PQR as indicated at Sl. No. 1 above

- A. Bidder's Experience list of IDCT for last 10 years for assessment of bidder for supplying the IDCT on regular basis in enclosed format- Annexure-1.

Bidder shall furnish the PO copy/approved documents/ Dispatch details/commissioning protocol of minimum two executed Contracts along with the experience list.

- B. Bidder shall furnish any one from below in support of successful performance of IDCT for one year:

- i. Satisfactory Performance feedback certificates from End Customer (Owner) (in English) for at least Two (from different End customers (Owner)) successfully executed contracts which have been in use for atleast one year indicating salient features like year of commissioning of IDCT, rating of project, flow of IDCT, project name etc., date of issue of certificate and name/ designation of the certificate issuer for power plant/similar application industry.

OR

- ii. The bidder has been awarded two repeat contracts for IDCT from two different End Customer (Owner) / Purchaser (in English) for power plant/similar application industry. Repeat contract shall be considered when the second contract is given by the same purchaser/ owner after lapse of minimum 1 year from execution of first contract.

Supporting documents for execution of the Contract like, commissioning protocol/PG test report, etc. along with the PO Copy to be furnished, if bidder intends to submit the documents for Repeat Contracts

OR

PREPARED BY:

REVIEWED BY:

APPROVED BY:

NAME:
DESIGNATION / DEPT.:

NAME:
DESIGNATION / DEPT.:

NAME:
DESIGNATION / DEPT.: