

	<b>PRE-QUALIFICATION REQUIREMENTS FOR BARE GROUND CONDUCTOR FOR BELOW GROUND EARTHING</b>	PE-PQ-999-509-E003
		REVISION NO. 01    DATE    29/04/2016
		SHEET NO. 1 OF 1

<b>ITEMS</b> : Bare Ground Conductor for Below Ground Earthing	
<b>SCOPE</b> : Supply : YES; Erection & Commissioning : NO;	
1.0	Vendor should be a manufacturer of LT power cables.
2.0	Availability of test reports on Conductor to establish in-house capability to carry out all routine, type & acceptance tests as per relevant IS/ International Standards.
3.0	Manufactured and supplied LT Power cable sizes of minimum 240 sq. mm.
4.0	Capacity of manufacturing 100 km of LT Power cables per month.
5.0	Manufactured & supplied at least 200 km of LT Power cables in one or more orders and at least 30 km in one single order.
6.0	Minimum two (2) nos. purchase orders for LT Power cables shall be submitted which should not be more than Five (05) years old from the date of application for registration or date of techno-commercial bid opening (as applicable) for establishing continuity in business

**NOTE:**

Supplier to comply to "general points of PQR" available at <http://bhelpem.com/vensection/PMD/PMD.aspx>  
In case supplier is not OEM, the offer shall be evaluated as per point no 1 of "general points of PQR".

<b>PREPARED BY</b>  NAME: DESIGNATION:	<b>REVIEWED BY</b>  NAME: DESIGNATION:	<b>APPROVED BY</b>  NAME: DESIGNATION:
---	---	---