

PRE-QUALIFICATION REQUIRMENTS FOR CABLE TERMINATION & JOINTING KITS

PE-PQ-999-507-E004

REVISION NO. 02 DATE 29/04/2016

SHEET NO. 1 OF 1

ITEMS: Cable termination and Jointing kits

Vendor may be considered for evaluation for one or more type of Cable termination and Jointing kits:

Type 1 : Heat shrinkable [termination & jointing kits]

Type 2: Pre-moulded push on [termination kits]

Type 3: Cold shrinkable [termination & jointing kits]

Type 4 : Elastimold [termination & jointing kits]

Type 5: Tapex [termination & jointing kits]

SCOPE: Supply: YES; Erection & Commissioning: NO;

1	Manufactured & supplied cable termination and jointing kits for voltage grade 3.3kV to 21kV for cable termination kits and 1.1kV to 21kV for cable jointing kits.		
2	Availability of type test certificates as per applicable standards for the applicable type of cable termination and jointing kits.		
3	Vendor has his own facility for manufacturing & routine testing for the applicable type of cable termination and jointing kits.		
	OR		
	Vendor should have valid licensed agreement with original manufacturer of components for the applicable type of cable termination and jointing kits.		
4	Vendor should have capacity to supply 600 nos. cable termination and jointing kits per month for the applicable type of termination and jointing kits.		
5	Manufactured & supplied at least 1000 nos. termination & jointing kits of applicable type in one or more orders.		
6	Minimum two (2) nos. purchase orders for termination & jointing kits of applicable type shall be submitted which should not be more than five (5) years old from the date of application for registration or date of techno-commercial bid opening (as applicable) for establishing continuity in business.		

NOTE:

Supplier to comply to "general points of PQR" available at http://bhelpem.com/vensection/PMD/PMD.aspx In case supplier is not OEM, the offer shall be evaluated as per point no 1 of "general points of PQR".

PREPARED BY	REVIEWED BY	APPROVED BY	
NAME:	NAME:	NAME:	
DESIGNATION:	DESIGNATION:	DESIGNATION:	