

	PRE-QUALIFICATION REQUIREMENTS FOR LT PVC CONTROL CABLE	PE-PQ-999-507-E015
		REVISION NO. 03 DATE 29/04/2016
		SHEET NO. 1 OF 1

ITEMS : LT PVC Control Cable	
SCOPE : Supply : YES; Erection & Commissioning : NO;	
1.0	Vendor should be a manufacturer of LT control cables.
2.0	Availability of test reports of tests of LT PVC/HRPVC FRLS control cables to establish in- house capability to carry out all routine, type & acceptance tests as per relevant IS/ International Standards (except UV radiation & hydrolytic stability test which can be conducted at Govt. Lab/ Govt. approved Independent lab).
3.0	Capacity of manufacturing 200 km of LT control cables per month.
4.0	Manufactured and supplied at least one (1) km of FRLS cables.
5.0	Manufactured and supplied LT control cables upto 12 cores.
6.0	Manufactured & supplied at least 500 km of LT control cables in one or more orders and at least 100 km in one single order.
7.0	Minimum two (2) nos. purchase orders for LT PVC / HRPVC control cables shall be submitted which should not be more than five (5) years old from the date of application for registration or date of techno- commercial bid opening (as applicable) for establishing continuity in business

NOTE:

Supplier to comply to "general points of PQR" available at <http://bhelpem.com/vensection/PMD/PMD.aspx>
In case supplier is not OEM, the offer shall be evaluated as per point no 1 of "general points of PQR".

PREPARED BY NAME: DESIGNATION:	REVIEWED BY NAME: DESIGNATION:	APPROVED BY NAME: DESIGNATION:
---	---	---