

	PRE-QUALIFICATION REQUIREMENTS FOR TREFOIL CLAMPS	PE-PQ-999-507-E005
		REVISION NO. 02 DATE 29/04/2016
		SHEET NO. 1 OF 1

ITEMS : Trefoil clamps

Vendor may be considered for evaluation for either or both type of trefoil clamps :

Type 1 – Nylon-6 material

Type 2 – Aluminium alloy

SCOPE: Supply : YES; Erection & Commissioning : NO;

1	Manufactured & supplied applicable type of trefoil clamps for single core cable of minimum overall dia. of 50 mm.
2	Availability of type test certificates (for short circuit at 125kA peak or above) for the applicable type of trefoil clamps.
3	Vendor has his own facility for manufacturing applicable type of trefoil clamps: a) Nylon-6 material b) Aluminium alloy
4	Manufacturing capacity of 10000 nos. per month for the applicable type of trefoil clamps.
5	Manufactured & supplied at least 20000 nos. trefoil clamps of applicable type in one or more orders.
6	Minimum two (2) nos. purchase orders for trefoil clamps of applicable type shall be submitted which should not be more than five (5) years old from the date of application for registration or date of techno-commercial bid opening (as applicable) for establishing continuity in business.

NOTE:

Supplier to comply to “general points of PQR” available at <http://bhelpem.com/vensection/PMD/PMD.aspx>
In case supplier is not OEM, the offer shall be evaluated as per point no 1 of “general points of PQR”.

PREPARED BY NAME: DESIGNATION:	REVIEWED BY NAME: DESIGNATION:	APPROVED BY NAME: DESIGNATION:
--	--	--